



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Tuesday, January 28, 2025, 12:00 pm – 1:30 pm

REPORT SUBMITTED: Friday, January 31, 2025

LOCATION OF OVERFLOW: [1011 Walker Swamp Road/Lower Poplar Brick Lift Station](#)

– Lift Station ID: 72

(Please note that the address used is a reference for the location of the force main.)

CAUSE OF OVERFLOW: This minor overflow resulted from a leaking force main.

ESTIMATED VOLUME DISCHARGED: 1,170 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Bay Street/Downtown

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, January 28, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: The force main has been repaired.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones