



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Dwight Jones

Valerie Wynn

Bill Howell

Desmond Brown

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Friday, April 5, 2024, 12:33 pm – 1:15 pm

REPORT SUBMITTED: Monday, April 8, 2024

LOCATION OF MINOR SPILL: [103 Merion Park](#) - MH ID: 63695
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was grease. There are no commercial sources of grease upstream from this location and residential grease is not regulated.

ESTIMATED VOLUME DISCHARGED: 759 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Ditch feeding Wolf Creek

SERVICE BASIN AFFECTED: Wolf Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Friday, April 5, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: The details of this minor spill have been forwarded to our Grease Management team for further investigation. The line is scheduled to be cleaned with grease emulsifier and televised. It will also be added to the Hotspot Inspection list for monitoring.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones