



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Calder B. Clay III

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MINOR SPILL REPORT TO EPD

EPD Watershed Protection Branch
2 Martin Luther King, Jr. Drive
Suite 1152
Atlanta, GA 30334

DATE OF MINOR SPILL: Monday, October 14, 2024, 11:45 am – 5:45 pm

REPORT SUBMITTED: Thursday, October 17, 2024

LOCATION OF MINOR SPILL: [1975 Deerwood Place](#) - MH ID: Unmapped manhole
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MINOR SPILL: After the blockage was removed, it was determined that the cause of this minor spill was due to root intrusion.

ESTIMATED VOLUME DISCHARGED: 7,200 gallons
(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)

RECEIVING WATERS: Walnut Creek

SERVICE BASIN AFFECTED: Walnut Creek

WRF SERVICE AREA NPDES PERMIT: GA0024538

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Monday, October 14, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: This line is scheduled to be cleaned and televised. It will also be added to the Hotspot Inspection list for ongoing monitoring. Additionally, the line is expected to undergo chemical treatment to address root intrusion. The manhole will be added to our mapping system.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones