



OVERFLOW REPORT

BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Elaine H. Lucas

Desmond Brown

Dwight Jones

Bill Howell

Valerie Wynn

Ron Shipman

Executive Director

& President

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

DATE OF OVERFLOW: Saturday, February 15, 2025, 12:53 pm – 2:30 pm

REPORT SUBMITTED: Monday, February 17, 2025

LOCATION OF OVERFLOW: [1987 Wood Valley Road](#) – MH ID: 60037
(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF OVERFLOW: After clearing the blockage, we determined that the minor overflow was caused by grease and debris in the sewer main. Commercial sources of grease have been identified upstream from this location.

ESTIMATED VOLUME DISCHARGED: 1,164 gallons
*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

SERVICE BASIN AFFECTED: Walnut Creek

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:
The blockage has been cleared, and debris has been removed. This area has also been sprayed with an enzyme treatment for organic waste called Bio-bug.

OVERFLOW STATUS: Sewage is no longer escaping.

SIGNS POSTED: Saturday, February 15, 2025

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE OVERFLOW: This line is scheduled for cleaning and CCTV inspection. It will also be added to the Hotspot Inspection list for ongoing monitoring. The details of this overflow have been forwarded to our Grease Management team for further investigation.

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph and Macon-Bibb County Health Department

REPORT SUBMITTED BY: Bryan Jones