



BOARD MEMBERS

Gary Bechtel

Chairman

Frank Patterson

Vice-Chairman

Dwight Jones

Valerie Wynn

Bill Howell

Desmond Brown

Ron Shipman

*Executive Director
& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MAJOR SPILL REPORT TO EPD

EPD Watershed Protection Branch

2 Martin Luther King, Jr. Drive

Suite 1152

Atlanta, GA 30334

DATE OF MAJOR SPILL: Tuesday, March 12, 2024, 10:15 am – 1:15 pm

REPORT SUBMITTED: Friday, March 15, 2024

LOCATION OF MAJOR SPILL: [3040 Greenbriar Road East](#) - MH ID: 57510

(Please note that the address used is a reference for the location of the manhole.)

CAUSE OF MAJOR SPILL: After the blockage was removed, it was determined that the causes of this spill were debris and sand.

ESTIMATED VOLUME DISCHARGED: 33,120 gallons

*(Please note that this quantity is only a calculated **estimation** of the volume of sewage that spilled from our system. More sewage may have escaped the system.)*

RECEIVING WATERS: Unnamed ditch feeding Rocky Creek

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Debris has been removed from the area. The affected area has also been sprayed with an enzyme treatment for organic waste called Bio-Bug.

SPILL STATUS: Sewage is no longer escaping.

SIGNS POSTED: Tuesday, March 12, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:

MWA has contacted a contractor to investigate approximately 2,500 linear feet which will use CCTV/Sonar to analyze any sediment and corrosion in the sewer line.

MONITORING INITIATED: Friday, February 16, 2024

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones