



BOARD MEMBERS

Gary Bechtel

Chairman

Dr. Anissa Jones

Vice-Chairman

Frank Patterson

Desmond Brown

Dwight Jones

Valerie Wynn

Bill Howell

Ron Shipman

*Executive Director
& President*

790 Second Street

P.O.Box 108

Macon, GA 31202

(478) 464-5600

Fax: (478) 750-2007

MaconWater.org

MAJOR SPILL REPORT TO EPD

EPD Watershed Protection Branch

2 Martin Luther King, Jr. Drive

Suite 1152

Atlanta, GA 30334

DATE OF MAJOR SPILL: Sunday, March 3, 2024

REPORT SUBMITTED: Thursday, March 7, 2024

LOCATION OF MAJOR SPILL: [Outfall/Discharge to Ocmulgee River from the Rocky Creek Water Reclamation Facility at 4705 Mead Road](#)

CAUSE OF MAJOR SPILL: High solids caused the WRF to exceed its daily threshold of Total Suspended Solids (TSS) as stated in the Authority's National Pollutant Discharge Elimination System Permit (NPDES).

MEASURED TSS EFFLUENT RESULT: The Georgia EPD requires Rocky Creek WRF to report as a Major Spill if the discharge to the waters of the State exceeds on any single day 67.5 mg/L for TSS. The TSS for the date reported was 133 mg/L.

VOLUME OF EFFLUENT DISCHARGED: 22.85 MG

RECEIVING WATERS: Ocmulgee River

SERVICE BASIN AFFECTED: Lower Rocky Creek

WRF SERVICE AREA NPDES PERMIT: GA0024546

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Aerators in the affected area of the plant were immediately shut down to hold solids in the basins until plant flows decreased, then were turned on slowly as plant conditions allowed to keep from overloading the clarifiers.

SPILL STATUS: Contained

SIGNS POSTED: March 5, 2024

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: Our staff has been working to get the aerators in the affected area of the plant back on. As many aerators are being run as possible across the rest of the plant to move the excess inventory through the treatment system and provide better solids breakdown; they are slowed or shut down only as necessary to hold solids in the aeration basins. Staff is also making continual adjustments to the aeration basins and clarifiers, when possible, to manage the solids onsite without any more loss to the effluent. We have clarifier polymer feed systems set up on standby to aid in solids settling. Wasting of excess solids is ongoing, and pressing is being done continuously while storage capacity is available. In addition, the MWA staff is still pursuing options for plant

expansion to provide additional treatment and volume.

MONITORING INITIATED: Monday, March 4, 2024

MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Macon Telegraph, WMAZ (TV), WMGT (Radio), WGXA, Macon-Bibb County Health Department, State of Georgia Health Department

REPORT SUBMITTED BY: Bryan Jones